## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client: **EC Group** 

PO Box 376

Edwardstown SA 5039

Test Number :

19-004575

**Issue Date** 

25/10/2019

**Print Date** 

25/10/2019

**Sample Description** 

Clients Ref:

"26oz Solution Dyed Nylon Loop"

Loop Pile Carpet Flooring End Use:

Nominal Composition:

Solution Dyed Nylon

AS/ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

**Radiant Heat Source** 

Date of Sample Arrival

**Date Tested** 

09/09/2019

24/10/2019

**CHF Value** 

1 10.7 2

3

Mean

· kW/m<sup>2</sup> 10.7 kW/m<sup>2</sup>

HF-30 Value

Length

Width

10.7

10.7 2 10.6 3

Mean

Length Width

· kW/m<sup>2</sup> · kW/m<sup>2</sup>

Smoke Value Length

1 19 21

2 31

3 33 Mean · %.min

28 %.min

Melting

Width

Yes

183923

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved

38254

Page 1 of 2



Accredited for compliance with ISO/IEC 17025 - Testing -Chemical Testing

-Mechanical Testing -Performance & Approvals Testing

Accreditation No. Accreditation No. :Accreditation No.

983 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltdmakes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall berendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



A JACKSON B.Sc.(Hons)

## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client: **EC** Group

PO Box 376

Edwardstown SA 5039

Test Number :

19-004575

**Issue Date** 

25/10/2019

**Print Date** 

25/10/2019

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon

HF30 not reported as flame out time occurred before 30 minutes.

183923

Copyright - All Rights Reserved

38254

Page 2 of 2



Accredited for compliance with ISO/IEC 17025 - Testing -Chemical Testing -Mechanical Testing

-Performance & Approvals Testing

Accreditation No. Accreditation No

983 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltdmakes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall berendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd. may be used in advertising providing the content and format of the advertis the Managing Director of AWTA Ltd.

A. JACKSON B.Sc.(Hons)

0204/11/06

APPROVED SIGNATORY